



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Metals in Drinking
 Water
 Analysis Report

Client: Paul D Sakson Associates Inc
 P.O. Box 154
 Leonardo, NJ 07737-0154

Report Number: 23-08-00616

Received Date: 08/03/2023

Reported Date: 08/09/2023

Project/Test Address: Growing Tree; N Plainfield; 334 Somerset Street; North Plainfield, NJ 07060

Client Number:
 201717

Laboratory Results

Fax Number:
 855-710-7460

Lab Sample Number	Client Sample Number	Collection Location	Analysis Date	Analyte	Concentration ppb (ug/L)	Narrative ID
23-08-00616-001	1	BOYS BATHROOM 1ST FLOOR	08/09/2023	Copper (Cu)	276	
			08/09/2023	Lead (Pb)	4.82	
23-08-00616-002	2	GIRLS BATHROOM 1ST FLOOR RIGHT SINK	08/09/2023	Copper (Cu)	300	
			08/09/2023	Lead (Pb)	<1.00	
23-08-00616-003	3	KITCHEN SINK 2ND FLOOR	08/09/2023	Copper (Cu)	725	
			08/09/2023	Lead (Pb)	1.26	
23-08-00616-004	4	STAFF BATHROOM 2ND FLOOR	08/09/2023	Copper (Cu)	312	
			08/09/2023	Lead (Pb)	4.88	